

Op. Co.	Date Application	WO # / Application ID	Town	Max Size (kW AC)	Fuel Source Type	Station Name	Eversource PPA Level	Eversource PPA Level Justification	ISO-NE PPA Level	ISO-NE PPA Level Justification
WMECO	6/13/2019	3286203	Tolland	5000		19J BLANDFORD	Level 3	System size >= 5 MW	Level 3	System size >= 5 MW
WMECO	6/21/2021	5852516	Springfield	2040	Solar	27A ORCHARD	Level 0 TL	Proposed + running will make total between 5 MW & 20MW. Prescreen needed.	Level 0	Proposed + running will make total between 5 MW & 20MW. Confirmation of no adverse impact
WMECO	6/30/2021	6020066	Chicopee	4999	Battery Only	21N PIPER	Level 0	<=5MW aggregate at station	Level 0	<=5MW aggregate at station
WMECO	7/21/2021	6196679	Ashfield	4999	Battery Only	38A ASHFIELD	Level 3	Level 3 by aggregate. Electrical Proximity to Berkshire, Plainfield, Cumberland and Montague	Level 3	Level 3 by aggregate. Electrical Proximity to Berkshire, Plainfield, Cumberland and Montague
WMECO	8/23/2021	6464754	Agawam	2000	Battery Only	30A SILVER	Level 0	<=5MW aggregate at station	Level 0	<=5MW aggregate at station
WMECO	10/12/2021	6846910	Ludlow	2000	Solar + Battery	27A ORCHARD	Level 0 TL	Proposed + running will make total between 5 MW & 20MW. Prescreen needed.	Level 0	Proposed + running will make total between 5 MW & 20MW. Confirmation of no adverse impact
WMECO	10/26/2021	7024635	Southampton	2000	Solar + Battery	15A GUNN	Level 0 TL	Proposed + running will make total between 5 MW & 20MW. Prescreen needed.	Level 0	Proposed + running will make total between 5 MW & 20MW. Confirmation of no adverse impact
WMECO	11/8/2021	7055112	West Springfield	1610	Solar + Battery	21N PIPER	Level 0	<=5MW aggregate at station	Level 0	<=5MW aggregate at station
WMECO	12/14/2021	7372844	Bernardston	2200	Solar + Battery	21B FRENCH KING	Level 3	Electrical proximity to other projects that aggregate in excess of 20MW	Level 3	Electrical proximity to other projects that aggregate in excess of 20MW
WMECO	1/20/2022	7596545	Agawam	4990	Battery Only	30A SILVER	Level 0 TL	Running total = 6.303 MW. Proposed + running will make total between 5 MW & 20MW. Prescreen needed.	Level 0	Running total = 6.303 MW. Proposed + running will make total between 5 MW & 20MW. Confirmation of no adverse impact.
WMECO	2/10/2022	7738165	Southwick	4000	Solar	29A Southwick	Level 3	This project will put the aggregate at southwick over 20MW	Level 3	This project will put the aggregate at southwick over 20MW
WMECO	2/28/2022	7791028	ERVING	2600	Battery Only	21C MONTAGUE	Level 3	Electrical proximity to other projects that aggregate in excess of 20MW	Level 3	Electrical proximity to other projects that aggregate in excess of 20MW
WMECO	2/10/2022	7805140	Chicopee	4100	NG	21N PIPER	Level 0 TL	Proposed + running will make total between 5 MW & 20MW. Prescreen needed.	Level 0	Proposed + running will make total between 5 MW & 20MW. Confirmation of no adverse impact
WMECO	2/22/2022	7818782	Hinsdale	4999	Battery Only	18C BERKSHIRE	Level 3	Electrical proximity to other projects that aggregate in excess of 20MW	Level 3	Electrical proximity to other projects that aggregate in excess of 20MW
WMECO	3/17/2022	7888442	Pittsfield	4990	Battery Only	19A DOREEN	Level 3	Electrically Close to Berkshire, Plainfield, Ashfield, Pleasant, Oswald, Partridge, and Woodland Road	Level 3	Electrically Close to Berkshire, Plainfield, Ashfield, Pleasant, Oswald, Partridge, and Woodland Road
WMECO	5/26/2022	9099859	Huntington	5000	Solar	19J BLANDFORD	Level 3	Individual size >=5MW	Level 3	Individual size >=5MW
WMECO	5/26/2022	9106188	Huntington	4250	Solar	19J BLANDFORD	Level 3	Part of cluster/ASO Study	Level 3	Part of cluster/ASO Study
WMECO	6/23/2022	9119667	Pittsfield	1500	Solar	30B OSWALD	Level 3	Electrically close to Oswald, Doreen, Partridge, Blandford, Berkshire, Woodland	Level 3	Electrically close to Oswald, Doreen, Partridge, Blandford, Berkshire, Woodland
WMECO	8/16/2022	10110145	Springfield	4999.2	Battery Only	21S CLINTON	Level 0	Running total = 0 MW. Proposed + running will make total < 5MW	Level 0	Running total = 0 MW. Proposed + running will make total < 5MW
WMECO	9/7/2022	10134769	Cheshire	4160	Solar + Battery	19A DOREEN	Level 3	Electrically close to Oswald, doreen, partridge, blandford, berkshire, woodland, pleasant	Level 3	Electrically close to Oswald, doreen, partridge, blandford, berkshire, woodland, pleasant
WMECO	9/13/2022	10306777	Conway	4400	Solar + Battery	38A ASHFIELD	Level 3	Electrically close to Berkshire, Plainfield, Cumberland, and Montague	Level 3	Electrically close to Berkshire, Plainfield, Cumberland, and Montague
WMECO	9/16/2022	10348567	West Springfield	4000	Solar + Battery	8C WEST SPRINGFIELD	Level 0	Running total = 0 MW. Proposed + running will make total < 5MW	Level 0	Running total = 0 MW. Proposed + running will make total < 5MW
WMECO	9/13/2022	10398207	Granville	3000	Solar + Battery	29A SOUTHWICK	Level 3	Running total = 18.09 MW. Proposed + running will make total > 20MW	Level 3	Running total = 18.09 MW. Proposed + running will make total > 20MW
WMECO	10/13/2022	10494103	Lanesborough	4000	Solar + Battery	15E PARTRIDGE	Level 3	Running total + system size > 20 MW	Level 3	Running total + system size > 20 MW
WMECO	10/4/2022	10496789	Dalton	10812	Battery Only	18C BERKSHIRE	Level 3	Above 5 MW system size	Level 3	Above 5 MW system size
WMECO	10/4/2022	10591149	Sunderland	20000	Battery Only	18G PODICK	Level 3	Electrically close to Cumberland, French King, Tilton, and Montague	Level 3	Electrically close to Cumberland, French King, Tilton, and Montague
WMECO	10/4/2022	10629918	Greenfield	17420	Battery Only	21C MONTAGUE	Level 3	System size >= 5 MW	Level 3	System size >= 5 MW
WMECO	10/13/2022	10751486	Lee	3000	Battery Only	16B PLEASANT	Level 3	Electrically Close: Berkshire, Plainfield, Ashfield, Doreen, Oswald, Partridge, Woodland Road, and Blandford	Level 3	Electrically Close: Berkshire, Plainfield, Ashfield, Doreen, Oswald, Partridge, Woodland Road, and Blandford
WMECO		10771048	Hadley	3830		17K AMHERST	Level 3	Electrically Close: Amherst, Gunn, Orchard, Piper	Level 3	Electrically Close: Amherst, Gunn, Orchard, Piper
WMECO	12/5/2022	11000115	SPRINGFIELD	2000	Battery Only	CLINTON	Level 0 TL	Running total = 4.999 MW. Proposed + running will make total between 5 MW & 20MW. Prescreen needed.	Level 0	Running total = 4.999 MW. Proposed + running will make total between 5 MW & 20MW. Confirmation of no adverse impact.
WMECO	12/5/2022	11160720	Feeding Hills	2000	Solar + Battery	30A SILVER	Level 0 TL	Running total = 11.263 MW. Proposed + running will make total between 5 MW & 20MW. Prescreen needed.	Level 0	Running total = 11.263 MW. Proposed + running will make total between 5 MW & 20MW. Confirmation of no adverse impact.
WMECO	12/5/2022	11309674	Blandford	2000	Solar	19J BLANDFORD	Level 3	Electrically close to Oswald, Doreen, Partridge, Berkshire, Woodland, and Pleasant	Level 3	Electrically close to Oswald, Doreen, Partridge, Berkshire, Woodland, and Pleasant
WMECO	12/5/2022	11332906	Becket	2700	Solar	19J BLANDFORD	Level 3	Electrically close to Oswald, Doreen, Partridge, Berkshire, Woodland, and Pleasant	Level 3	Electrically close to Oswald, Doreen, Partridge, Berkshire, Woodland, and Pleasant
WMECO	12/29/2022	11575750	Blandford	4988	Solar + Battery	19J BLANDFORD	Level 3	Electrically close to Oswald, Doreen, Partridge, Berkshire, Woodland, and Pleasant	Level 3	Electrically close to Oswald, Doreen, Partridge, Berkshire, Woodland, and Pleasant
WMECO	12/29/2022	11576334	Blandford	4998	Solar + Battery	19J BLANDFORD	Level 3	Electrically close to Oswald, Doreen, Partridge, Berkshire, Woodland, and Pleasant	Level 3	Electrically close to Oswald, Doreen, Partridge, Berkshire, Woodland, and Pleasant
WMECO	1/23/2023	11787628	Montague	11000	Battery Only	21C MONTAGUE	Level 3	System size >= 5 MW	Level 3	System size >= 5 MW

WMECO	2/2/2023	11788999	Springfield	2233	Solar + Battery	20A BRECKWOOD	Level 0 TL	Proposed + running will make total between 5 MW & 20MW. Prescreen needed.	Level 0	Proposed + running will make total between 5 MW & 20MW. Confirmation of no adverse impact.
WMECO	2/2/2023	11789116	Springfield	3550	Solar + Battery	20A BRECKWOOD	Level 0	Proposed + running will make total < 5MW	Level 0	Proposed + running will make total < 5MW
WMECO	2/1/2023	11852935	Conway	4200	Solar	22B Cumberland	Level 3	Cumberland was part of the 2021 ASO Study	Level 3	Cumberland was part of the 2021 ASO Study
WMECO	2/1/2023	11853302	Springfield	4999	Battery Only	Orchard 27A	Level 3	Orchard is electrically close to Ludlow	Level 3	Orchard is electrically close to Ludlow
WMECO	2/15/2023	12021288	PITTSFIELD	2000	Solar	17K AMHERST	Level 3	Electrically Close: Amherst, Gunn, Orchard, Piper	Level 3	Electrically Close: Amherst, Gunn, Orchard, Piper
WMECO	2/17/2023	12049715	SPRINGFIELD	4999	Battery Only	20A BRECKWOOD	Level 0 TL	Running total = 3.783 MW. Proposed + running will make total between 5 MW & 20MW. Prescreen needed.	Level 0	Running total = 3.783 MW. Proposed + running will make total between 5 MW & 20MW. Confirmation of no adverse impact.
WMECO	3/22/2023	12371149	Southwick	6700	Solar + Battery	29A Southwick	Level 3	System size >= 5 MW	Level 3	System size >= 5 MW
WMECO	5/5/2023	12538778	Plainfield	7000	Solar + Battery	18K PLAINFIELD	Level 3	System size >= 5 MW	Level 3	System size >= 5 MW
WMECO	5/5/2023	12907802	Springfield	4999	Battery Only	27A ORCHARD	Level 3	Electrically close to Piper, Fairmont, and Amherst	Level 3	Electrically close to Piper, Fairmont, and Amherst
WMECO	5/12/2023	12958986	Montague	11100	Battery Only	21C MONTAGUE	Level 3	Proposed + existing will make running total > 20MW	Level 3	System size >= 5 MW
WMECO	5/24/2023	13027100	Worthington	3000	Solar + Battery	18K PLAINFIELD	Level 3	Electrically Close to Berkshire, Ashfield, Doreen, Oswald, Partridge, and Woodland Road	Level 3	Electrically Close to Berkshire, Ashfield, Doreen, Oswald, Partridge, and Woodland Road
WMECO	5/31/2023	13159871	Becket	4999	Solar + Battery	16B PLEASANT	Level 3	Electrically Close to Berkshire, Plainfield, Ashfield, Doreen, Oswald, Partridge, and Woodland Road	Level 3	Electrically Close to Berkshire, Plainfield, Ashfield, Doreen, Oswald, Partridge, and Woodland Road
WMECO	6/6/2023	13187454	Montague	4000	Battery Only	21C MONTAGUE	Level 3	Proposed + existing will make running total > 20MW	Level 3	Proposed + existing will make running total > 20MW
WMECO	6/2/2023	13237745	Worthington	2000	Solar + Battery	18K PLAINFIELD	Level 3	Electrically Close to Berkshire, Ashfield, Doreen, Oswald, Partridge, and Woodland Road	Level 3	Electrically Close to Berkshire, Ashfield, Doreen, Oswald, Partridge, and Woodland Road
WMECO	7/13/2023	13731248	Blandford	3000	Solar + Battery	19J BLANDFORD	Level 3	Proposed + existing will make running total > 20MW	Level 3	Proposed + existing will make running total > 20MW
WMECO	8/3/2023	14019551	Montague	4999	Battery Only	21C MONTAGUE	Level 3	Proposed + existing will make running total > 20MW	Level 3	Proposed + existing will make running total > 20MW
WMECO	8/2/2023	14034106	Southwick	2000	Solar	29A SOUTHWICK	Level 3	Proposed + existing will make running total > 20MW	Level 3	Proposed + existing will make running total > 20MW
WMECO	8/9/2023	14119750	Southwick	4998	Solar + Battery	29A SOUTHWICK	Level 3	Proposed + existing will make running total > 20MW	Level 3	Proposed + existing will make running total > 20MW
WMECO	8/17/2023	14208240	Agawam	2000	Solar	30A SILVER	Level 3	Electrically Close: Gunn, Piper, Agawam, etc.	Level 3	Electrically Close: Gunn, Piper, Agawam, etc.