

Environmental Spills during Storm Restoration



During an ERP, Eversource personnel and contractors that encounter spills or leaking oil-filled equipment are required to **take immediate action and provide correct details** to ensure compliance.

CT—IMPORTANT NOTICE:

LEAKING Oil-Filled Equipment.

This includes seeping or weeping.

If you are **NOT** an environmental contractor, **DO NOT** transport from its original location.

NOT LEAKING, Oil-Filled Equipment

Transport to the applicable work center and store in the proper storage area.

Steps for Spills and Leaking Equipment — Remember ABC:

A

Assess and contain the spill (berm with spill kit if available).

B

Bag the leaking equipment and leave at the original location.

C

Call the Environmental Event Room Immediately at **888-957-7455**.

Provide accurate and complete information:

- Pole or Pad Number
- Street address referencing nearest house number and cross street
- Town
- Your Name and callback number
- Estimated quantity of oil released
- Impacted surfaces, including observation of any waterway impact
- Equipment manufacturer, serial #, ppm PCB of the transformer (nameplate/sticker)
- If the area is safe/accessible for our spill cleanup vendor

Reminder — **Leaking equipment must not be** transported from its outage location to any other location, e.g., work centers or staging areas. **Equipment should be disconnected**, bagged and made accessible.