

## **Technical Notice for Distributed Generator Interconnections**

This is to notify you that effective immediately, all inverter based generation with an aggregate capacity of 100 kW or larger that will be interconnected to the Eversource electric distribution system must comply with the Northeast Power Coordinating Council (NPCC) A-03 under-frequency load-shedding requirements. NPCC A-03 requires that generators trip for under frequency events at 57 HZ with a time delay of 0.16 seconds.

Eversource will verify the under-frequency settings during the witness test but requires that factory test indicating those settings be submitted to Eversource prior to the witness test. Should you have any questions please do not hesitate to contact Eversource at 866-324-2437.